



JCM 429 Fabricated Tapping Sleeve with Mechanical Joint Outlet*

INSTALLATION INSTRUCTIONS

Thoroughly clean pipe surface. Check the size and range of the tapping sleeve to verify correct size product. Check pipe surface where gasket will seat to make certain pipe is free of flaws, gouges and extreme irregularities.

Lubricate pipe and face of gasket with soap-water or gasket lubricating solution. **Do not** use grease or pipe lubricant.

Position outlet half of body on pipe, making sure outlet is aligned with branch line to be connected. Never position so that rotation is required.

Position back half of body and install bolts. (For fittings provided with stainless steel hardware, see reverse side.) NOTE: If you are pre-assembling valve to tapping sleeve prior to installing sleeve, **install center** bolts in size on size sleeves prior to installing the valve.

Tighten bolts evenly, alternating from one side to the other. Start with outside bolts and work toward center bolts. Tighten to the following torque levels:

Thin Wall, PVC (SDR21, 26) Pipe, Flexible Pipe -	50 - 55 ft. lbs. of torque
HDPE SDR 11, SDR 17, Steel Pipe -	55 - 60 ft. lbs. of torque
Steel and Rigid Wall Pipe -	75 ft. lbs. of torque minimum

Check inside of sleeve neck to make certain gasket is properly seated and not protruding where tapping cutter may damage it.

Install MJ connection (valve, fitting, etc). Place the MJ gasket on the alignment stem above the flange. Push gasket on until it is seated on the gasket backer. Place MJ valve/fitting over alignment stem. Insert flange bolts at the 11 and 1 o'clock positions, then place nuts on bolts. Install the remaining flange bolts. Tighten flange bolts evenly to a minimum of 90 ft. lbs. of torque making sure the gap between the two flanges is equally spaced around the outlet. Ensure proper alignment of the fitting to the outlet (i.e. cutter travel). Place the 1/2" load bearing set pins in tapped holes and tighten set pins to minimum of 50 ft. lbs of torque. JCM recommends adherence to the AWWA M-44 Manual for proper valve installation, support and trenching.

Test assembly seals with water (per AWWA C-223) using test plug provided on sleeve or test connection on tapping machine. Note: No more than 10% above line pressure on HDPE or maximum pipe working pressure rating.

When assured that all seals are tight and test is completed, re-check bolt torques after 15 minutes and proceed with tapping operation.

Note: Size on size tapping cutter must not be larger than recommended by pipe manufacturer. Also, tapping operation must not force the pipe away from the gasket seal.

*Licensed by PowerSeal Corporation U.S. Patent #6,227,234



Recommendations For Installation Of Fittings With Stainless Steel Bolts And Nuts

This JCM Quality Fitting is equipped with 18-8 stainless steel bolts and nuts for superior corrosion resistance. It is the nature of stainless steel fasteners to gall and freeze if not properly handled. This undesirable characteristic is due to the inherent properties of the stainless material. The galling and freezing action is often triggered by the presence of metal chips, burrs and grains of sand on the threads of the bolts and nuts.

Extra care has been taken by JCM prior to assembly and packing of this fitting to assure a trouble-free installation.

1. The nuts and bolts are made from material of different hardness so that they have different strengths.
2. The nuts are coated with a special (antiseize) coating.
3. Each nut is assembled by hand to be sure that it went on the bolt freely.
4. The bolts and nuts are handled carefully to avoid damage to the threads.
5. The bolts and nuts are made to exacting specifications to assure that the correct material is used and that the thread form is correct.

However, it must be pointed out that during field installation, the threads **MUST BE KEPT CLEAN AND FREE FROM NICKS.**

When a mild steel or bronze bolt is used, the low ultimate strength of the material allows the nut to tear itself free. Not so with 18-8 Stainless Steel. The ultimate strength of the material is so great, that it increases rapidly with cold work. However, once foreign matter such as a grain of sand wedges the threads, or the thread form is altered by over-torquing, the nuts cannot be removed.

The specially coated nuts supplied by JCM help to eliminate the galling caused by overtorquing, but **the bolts must be kept clean and not pitched or thrown into the tool bucket during installation. Should additional lubrication be required, a Molybdenum-Base lubricant is recommended.**

NOTE: Installation of this fitting with a pneumatic wrench may cause seizure of the nut. **A JCM 901 Master Wrench or JCM 905 Torque Wrench with Deep Socket is recommended.**

INTSSB - 011306